




TSS Associates, Inc.



For further assistance, please contact
Ecobee directly for Tech Support

1-877-932-6233



Do NOT jumper **Rc** and **Rh**

NOTES:
PEK = Power Extender Kit = if there is no Common wire

TSS Associates, Inc.	
DESCRIPTION ECOBEE 3 LITE – BOSCH M15 – M15 AHU – HYDRO-COIL	
DATE: 1/2/2024	PAGE: 2 of 3

PARAMETERS:

- >> Transformer > **YES, ONLY Rc IS CONNECTED**
- >> Configuration > Make sure highlighted icons correspond with wires installed
- >> Equipment > **HEAT PUMP > AIR TO AIR**
- >> O/B Reversing Valve > **ON HEAT**
- >> Allow Heat Pump and Aux Heat to run simultaneously > **ENABLE**
- >> Compressor Minimum Outdoor Temperature > **WHATEVER TEMPERATURE IS DESIRED BASED UPON HOMEOWNER COMFORT AND ENERGY COSTS**

- >> Type of heating > **FURNACE**
- >> How do you want your fan to be controlled > **THERMOSTAT**

└─> **MAIN MENU > SETTINGS > INSTALLATION SETTINGS (ADVANCED OPTIONS) > THRESHOLDS:**

- >> Threshold Staging > **MANUAL**
- >> Auto Heat/Cool > **DISABLE**
- >> Compressor Minimum Cycle Off Time > **300 SEC**
- >> Aux Heat Max Outdoor Temperature > **WHATEVER TEMPERATURE IS DESIRED**
- >> Compressor to Aux Temperature Delta [droop] > **AUTO**
- >> Compressor to Aux Runtime > **60 MINUTES**

NOTES:

TSS Associates, Inc.

DESCRIPTION

ECOBEE 3 LITE – BOSCH M15 – M15 AHU – HYDRO-COIL

DATE: 11/2/2023

PAGE: 3 of 3